## **AWTA PRODUCT TESTING**

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400 Fax (03) 9371 2499

## **TEST REPORT**

Client: Aspecta Apac Pty Ltd

Unit 4

15 Shearson Crescent Mentone VIC 3194

Test Number : Issue Date :

18-001903 27/04/2018

Print Date

1/06/2018

**Sample Description** 

Clients Ref : "Strata Commercial"

Multilayer PVC flooring

Colour : Torino Oak - Bruno End Use : Floor Covering

Nominal Composition: 1xPE Backing, Isocore, PVC LVT, PVC Wear Layer

Nominal Thickness: 7.0mm

ISO 9239.1:2010 Part 1

Reaction to Fire Tests for Floorings. Determination of the Burning Behaviour using a Radiant Heat Source

Date of Sample Arrival 13/04/2018
Date Tested 26/04/2018

CHF Value 2 1 3 Mean Length 6.2 kW/m² Width 5.7 5.7 5.7 kW/m² Smoke Value 1 2 3 Mean Length 186 %.min Width 196 237 225 219 %.min

Melting Yes
Blistering Yes
Smouldering Yes

131141 26940 Page 1 of 2

C Australian Wool testing Authority Ltd Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Chemical Testing

Mechanical Testing

- Performance & Approvals Testing

: Accreditation No.

: Accreditation No.

983 985 1356

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.



MICHAEL A. JACKSON B.Sc.(Hons)

## **AWTA Product Testing**

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400 Fax (03) 9371 2499

## **TEST REPORT**

Client: Aspecta Apac Pty Ltd

Unit 4

15 Shearson Crescent Mentone VIC 3194

18-001903 Test Number :

**Issue Date** 27/04/2018 **Print Date** 1/06/2018

The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test, they are not intended to be sole criterion for assessing the potential fire hazard of the product in use.

Sample was conditioned in accordance with BSEN 13238:2010 at a temperature of 23±2°C and relative humidity of 50±5% for a minimum of 48 hours prior to testing.

Each specimen was clamped to a substrate of 6mm thick fibre reinforced cement board prior to testing.

131141 26940 Page 2 of 2

Australian Wool testing Authority Ltd Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Chemical Testing Mechanical Testing

Performance & Approvals Testing

: Accreditation No

Accreditation No

· Accreditation No. 1356

983

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.



A. JACKSON B.Sc.(Hons)

APPROVED SIGNATORY